

SCL Tooling - Issues #5154

Add 61869-9 sample rates to UCA conformance certificates?

01/11/2022 08:06 PM - Bruce Muschlitz

Status: Closed	Due date:
Priority: Normal	
Assignee:	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: Server Ed2.1 TP1.2
Clause Reference:	Test Case ID:
61850 Standard:	Closed Reason: Test Procedure Update
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document:	
Description	
<p>Redmine database has the capability to record the nominal frequencies, sampling rates, and variants (without dataset declared). However, Ed2.1 Certificates do not include this information (it was included on the 9-2LE (Ed1 publisher) certificates. Suggest to add that information to the certificate. Information frequency is limited to DC or 50Hz or 60Hz. Information on variants can be selected from: 9-2LE (legacy) rates: F4000S1, F4800S1, F5760S1, F12800S8, F15360S8 preferred rates: F4800S2, F14400S6, F96000S1</p> <p>Note that 61869-9 conformance test requires that each unique rate/nofASDU combination be individually tested (it allows a single data set to be chosen for each rate regardless of the number of analog channels available for that rate/nofASDU)</p>	
Related issues:	
Related to Server - Issues #5308: SV Publisher/subscriber maximum dataset siz...	Closed

History

#1 - 04/05/2022 08:13 AM - Herbert Falk

- Related to Issues #5308: SV Publisher/subscriber maximum dataset size is untested added

#2 - 06/02/2022 03:12 PM - Bruce Muschlitz

- Status changed from New to Closed
- Discuss in Upcoming Meeting changed from Yes to No
- Updated Test Document set to Server Ed2.1 TP1.2
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

See R5293 and R5308 for resolutions