

## IEC 61850 User Feedback Task Force - Support #518

**Does the SVID character have to be specifically mentioned to be within 10-34 characters? Some of the vendors have implemented th**

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b> Closed	<b>Start date:</b>
<b>Priority:</b> Normal	<b>Due date:</b>
<b>Assignee:</b>	<b>% Done:</b> 0%
<b>Category:</b>	<b>Estimated time:</b> 0.00 hour
<b>Target version:</b>	<b>To discuss in WG10:</b>
<b>ID:</b> 34	<b>Short Proposal:</b> 61869 has a should not SHALL for length.
<b>Source:</b> IOP_2015	<b>Standard(s):</b>
<b>TF Unique ID:</b> 34 # IOP_2015	<b>Needs More Information:</b>
<b>WG10 Proposal:</b>	<b>Assigned TF:</b>
<b>Estimated Completion:</b>	
<b>Discuss in Upcoming Meeting:</b>	
<b>Description</b>	
Does the SVID character have to be specifically mentioned to be within 10-34 characters? Some of the vendors have implemented the svID field in the configuration tool to have at least 10 characters. 1) Reference page 15/31 of Implementation guide of 9-2LE Rev2-1 2)Reference Page 27 of IEC 61869-9 working draft may 2015	

### History

#1 - 06/21/2022 09:12 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.