WG14 Part 1 Issues - CIM Issues #5180

Business functions on HAN / DER / EV

01/12/2022 02:43 PM - Herbert Falk

Status:	New		
Priority:	Normal		
Target version:			
Author/Contact Info:		**Standard(s):**	
Base Release:		**Version:**	
Solution to be Applied To:		**Clause:**	
Solution Version:		**Sub-Clause:**	
Solution Applied By:		**Paragraph:**	
Completion Date:		**Table:**	
CIM Keywords:		**Originally Closed in Version:**	
Breaking Change:	No	**Origination Date:**	05/15/2013
Breaking Change Description:		**Origination ID:**	23
CIM Impacted Groups:	WG13	**Originally Assigned To:**	
Requestor:			

Description

Proposed Solution

To be added into the EXT (External to DMS)

Decision

HAN is covered (PAN) under both Part 9 and External functions. DER functions related to Part-9 have been added and provided by Chris K. See Distributed Energy Resource Data Acquisition and Control (DERDAC) business sub function under Part-9. Should EV be treated as a DER or a special function? It is typically treated as distributed energy storage system. See DER Storage System sub-function under Part-9 DERDAC [2017-10-26]: DER is not special from business function perspective, so no DER specific functions need to be defined in IRM. Issue closed (Richland Meeting #63)