

## IEC 61850 User Feedback Task Force - Feature #522

### SCD file has "originalSciVersion=2007" for all IED, including Ed1 devices

02/03/2021 02:07 PM - Herbert Falk

|   |   |
|---|---|
| <b>Status:</b> Closed   | <b>Start date:</b>  |
| <b>Priority:</b> Normal   | <b>Due date:</b>  |
| <b>Assignee:</b>  | <b>% Done:</b> 0%   |
| <b>Category:</b> Standard extension required  | <b>Estimated time:</b> 0.00 hour  |
| <b>Target version:</b>  | <b>To discuss in WG10:</b>  |
| <b>ID:</b> 3  | <b>Short Proposal:</b> Edition 2.1 line 2509-2510 (of INF) states: "Both attributes are set by the IED tool when creating the ICD or IID file, and shall be kept within an SCD file."No issue for the standard. |
| <b>Source:</b> IOP_2017/5   | <b>Standard(s):</b> IEC 61850-6   |
| <b>TF Unique ID:</b> 3 # IOP_2017/5   | <b>Needs More Information:</b>  |
| <b>WG10 Proposal:</b> clarification needed in table 10 regarding originalSciVersion default value.Update below table 10 to force SCT to fill them -> OK | <b>Assigned TF:</b>   |
| <b>Estimated Completion:</b> Solved in IEC 61850-6 Ed 2.1   |   |
| <b>Discuss in Upcoming Meeting:</b> No  |   |

**Description**

SCD file has "originalSciVersion=2007" for all IED, including First Edition devices.

SCT should have added "2003" when originalSciVersion/OriginalSciRevision was not in ICD file.

#### History

##### #1 - 02/11/2021 07:39 AM - Vladan Cvejic

- Subject changed from SCD file has "originalSciVersion=2007" for all IED, including First Edition devices.

SCT should have added "2003" when original to SCD file has "originalSciVersion=2007" for all IED, including Ed1 devices

- Status changed from New to In Progress

- Short Proposal changed from Edition 2.1 line 2509-2510 (of INF) states: "Both attributes are set by the IED tool when creating the ICD or IID file, and shall be kept within an SCD file."

No issue for the standard.

to Edition 2.1 line 2509-2510 (of INF) states: "Both attributes are set by the IED tool when creating the ICD or IID file, and shall be kept within an SCD file."No issue for the standard.

- Standard(s) changed from 6 to IEC 61850-6

- WG10 Proposal changed from clarification needed in table 10 regarding originalSciVersion default value.

Update below table 10 to force SCT to fill them -> OK to clarification needed in table 10 regarding originalSciVersion default value.Update below table 10 to force SCT to fill them -> OK

- Discuss in Upcoming Meeting set to No

Checking done.

##### #2 - 06/21/2022 09:24 AM - Carlos Rodriguez del Castillo

- Status changed from In Progress to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.