

## IEC 61850 User Feedback Task Force - Support #525

### IEC 61850-6 does not allow the authentication configuration (none, password, weak, strong or certificate) to be used for Client

02/03/2021 02:07 PM - Herbert Falk

<b>Status:</b>	Resolved	<b>Start date:</b>	
<b>Priority:</b>	Normal	<b>Due date:</b>	
<b>Assignee:</b>		<b>% Done:</b>	0%
<b>Category:</b>	Standard extension required	<b>Estimated time:</b>	0.00 hour
<b>Target version:</b>		<b>To discuss in WG10:</b>	No
<b>ID:</b>	6	<b>Short Proposal:</b>	SCL must allow IEDs (client and server) to declare capabilities for security. Make the extension in 62351-6.
<b>Source:</b>	IOP_2017/8	<b>Standard(s):</b>	IEC 61850-6
<b>TF Unique ID:</b>	6 # IOP_2017/8	<b>Needs More Information:</b>	No
<b>WG10 Proposal:</b>	Wait for IEC 62351-6 IS and then address it in part 61850-6	<b>Assigned TF:</b>	
<b>Estimated Completion:</b>	61850-6 Ed2.2 (End of 2023)		
<b>Discuss in Upcoming Meeting:</b>	No		
<b>Description</b>			
IEC 61850-6 does not allow the authentication configuration (none, password, weak, strong or certificate) to be used for Client applications that do not include a server.			

#### History

##### #1 - 06/21/2022 09:17 AM - Carlos Rodriguez del Castillo

- Status changed from New to Resolved
- Discuss in Upcoming Meeting set to No
- To discuss in WG10 set to No
- Standard(s) changed from 6 to IEC 61850-6

IEC 61850-6 ed2.2 will include IEC 62351-6 extension.

##### #2 - 05/09/2023 08:49 AM - Carlos Rodriguez del Castillo

- Estimated Completion changed from Ask Frances to 61850-6 Ed2.2 (End of 2023)
- Needs More Information set to No