Server - Issues #5289

Ed2.1 Server TP 1.1 Does not include 2.0 server PIXIT Gs12

01/23/2022 08:30 PM - Bruce Muschlitz

Status: Closed Due date:

Priority: Normal

Assignee: Richard Schimmel

Category:

Target version:

Discuss in Upcoming No Updated Test Meeting: Updated Test

Clause Reference: Annex E (PIXIT) Test Case ID:

61850 Standard: Closed Reason: Test Procedure Update

Triggering Tissue: Triggering Tissue 2:
Final Decision: Triggering Tissue 3:

Initial Test UCATestProceduresServer61850-8-1Ed

Document: 2Amd1 Rev1p1

Description

Ed2.0 server TP 2.0.5 has Gs12 "Is IEC 62351-6 security supported (Y/N)".

This was missed in Ed2.1 TP where Gs12 is now "How does the subscriber handle incoming data flagged as test when the destination LN.Beh is On or Blocked?"

Ed2.1 added McSecurity which removed need for Ed2.0 PIXIT entry.

Suggest changes to Ed2.1 test procedures for pending Rev1.2:

- 1. Re-insert old Gs12 and mark as Ed2-only
- 2. Rename existing Gs12 to Gs13 in sGos23 references and PIXIT itself (no other changes needed

Related issues:

Related to Server - Issues #6255: ED2.0 TP2.0.6 has sGos23 but PIXIT template... Closed 03/07/2023

History

#1 - 02/22/2022 02:13 PM - Bruce Muschlitz

- Status changed from New to Closed
- Assignee set to Richard Schimmel
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set---)

Solution proposed by Richard in Ed2.1 Server TP_Rev1p2 draft 01.

UCAlug is now reviewing the draft for release by 31-March-2022.

Solution is to keep Gs12 from Ed2.0 procedures and rename the Gs12 in the new procedures as Gs13

#2 - 07/27/2022 10:39 AM - christian zehnder

In latest ServerTP_Ed2.0_2.0.6 sGos23 references to PIXIT Gs13. But Gs13 is missing in PIXIT within TP, nor does it exist in latest available "TemplatePixitServerEd1Ed2_rev20" from UCA templates.

#3 - 02/21/2023 08:29 AM - IEC 61850 TPWG

- Related to Issues #6255: ED2.0 TP2.0.6 has sGos23 but PIXIT template misses the entry Gs13 while in TP1.2 ED2.1 the Gs13 has Amd1 Ed only added

04/09/2024 1/1