

# IEC 61850 Certificate - IEC 61850 Certificate #5290

## saTECH SCU-HMI 122 [Arteche/SAC]

01/24/2022 12:59 PM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10301316-INC 21-3596
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: AB608A38062DFE9C696EFF3C5E89A7 86687CD6D2DA6A35CFF3B717872C80 50C9
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Arteche/SAC	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Derio Bidea 28, Zabalondo Industrialdea 48100 Mungia, Bizkaia Spain	<b>Umbrella Organization:</b>	Arteche
<b>Product:</b>	saTECH SCU-HMI 122	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	V.2.1.2	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/29/2021	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b> Station Control Unit			

### History

#1 - 01/24/2022 01:14 PM - Bruce Muschlitz

- Description updated
- Current Test Lab Name set to DNV Netherlands (A)
- Umbrella Organization set to Arteche

### Files

21-3596\_DNV\_SAC-Arteche\_saTECH SCU-HMI 122\_clientEd2\_Certificate.pdf

01/24/2022

Bruce Muschlitz