

# IEC 61850 Certificate - IEC 61850 Certificate #5291

## RTU194 [Controles S.A.]

01/24/2022 01:11 PM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10271907-INC 21-2526
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: AE6EFC29DCC87350AF1B8D14A70CD E529F59779015AEE06BB2AB35C6B0F 07012
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Controles S.A.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Av. Rivera 3314 CP 11300 Montevideo Uruguay	<b>Umbrella Organization:</b>	Controles
<b>Product:</b>	RTU194	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	F02-CP22-IA23-IB23-PA03-PB03-D02	<b>Serial Number:</b>	
<b>SW Version:</b>	RTUQM v5.2	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/11/2022	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
Remote Terminal Unit			

### Files

21-2526\_DNV\_Controles\_RTU194\_ServerEd2\_Certificate.pdf

117 KB

01/24/2022

Bruce Muschlitz