

Server - Issues #5292

sCnf125 smvOpts sampleSynchronized=true or absent, dataSet=false or absent

01/25/2022 03:54 AM - Richard Schimmel

Status: Closed	Due date:
Priority: Normal	
Assignee:	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: Server Ed2.1 TP1.2
Clause Reference: IEC 61850-6 Table 31	Test Case ID:
61850 Standard:	Closed Reason: Test Procedure Update
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Amd1 TP1.1	
Description	
IEC 61850-6 and IEC 61869-9 are not consistent related to smvOpt. Part 6 table 31 states smvOpts: dataRef and sampleSynchronized are deprecated but are kept in SCL for backwards compatible reasons. As such we have to update sCnf125:	
OLD:	
Verify the SmvOpts (clause 6.903.11)	
- SmvOpt: sampleSynchronized="true" refreshTime="false" sampleRate="false" dataSet="false" security="false"	
NEW:	
Verify the SmvOpts (clause 6.903.11 and IEC 61850-6 Table 31)	
- SmvOpt: sampleSynchronized="true" or absent; refreshTime="false"; sampleRate="false"; dataSet="false" or absent; security="false"	

History

#1 - 03/22/2022 07:13 PM - Bruce Muschlitz

- Status changed from In Progress to Resolved

Per TPWG meeting 2022-03-22, this is obvious typographical error to be fixed in Ed2.1 Server TP 1.2

#2 - 04/04/2022 07:21 AM - Richard Schimmel

Also smpMod=SmpPerPeriod **or absent**. Note that SmpMod shall be **s mpMod**.

#3 - 05/17/2022 06:45 AM - Richard Schimmel

Part 6 A.4 specifies default values for all SmvOpts options:

Verify the SmvOpts (clause 6.903.11 and IEC 61850-6 Table 31) and part 6 A.4

- SmvOpt:
sampleSynchronized="true" or absent;
refreshTime="false" or absent;
sampleRate="false" or absent;
dataSet="false" or absent;
security="false" or absent

#4 - 06/02/2022 02:57 PM - Bruce Muschlitz

- Status changed from Resolved to Closed

- Updated Test Document set to Server Ed2.1 TP1.2

- Closed Reason Test Procedure Update added

- Closed Reason deleted (--Not Set--)