

# IEC 61850 Certificate - IEC 61850 Certificate #5324

## SuperTAPP SG [Fundamentals Ltd]

03/15/2022 08:24 AM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10328222-DSO 22-2679
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: ABE709457393E7925E1485B5CCCABB F970AE24D4E258C7DD963B9928212D 9F9F
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Fundamentals Ltd	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Unit 2, Hillmead Enterprise Park Marshall Road, Swindon Wiltshire, SN5 5FZ United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	SuperTAPP SG	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	SN1034-201712-0005
<b>SW Version:</b>	Main software version: 9.4; Communication software version: 29	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), GOOSE Publish (9a), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/04/2022	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
Voltage Control & Monitoring Relay			

### Files

22-2679\_DNV\_Fundamentals\_SuperTAPPSG\_ServerEd2\_Certificate.pdf 12 KB

03/15/2022

Bruce Muschlitz