

IEC 61850 Certificate - IEC 61850 Certificate #5325

AVEVA Telemetry Server [AVEVA Solutions Ltd.]

03/21/2022 12:39 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10323567-INC 22-2594
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 6786F773F91FA23671A114335ACE791 3F8F4155E64264E0ACD5E8D90F8A40 BDF
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	AVEVA Solutions Ltd.	Vendor Artifact Hash:	
Address:	High Cross Madingley Road CB3 0HB Cambridge United Kingdom	Umbrella Organization:	Aviva
Product:	AVEVA Telemetry Server	Optional Reservation Test:	No
HW Version:	Dell Latitude 5400 with Windows 10 64 bit	Serial Number:	
SW Version:	6.84.8074.1	Publisher Legacy Variants:	
Key Words:	Gateway	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Service Tracking (B15), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/23/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Telemetry driver for AVEVA System Platform			

History

#1 - 03/21/2022 12:42 PM - Bruce Muschlitz

- File 22-2594_DNV_Aveva_Telemetry Server_clientEd2_Certificate.pdf added

Files

22-2594_DNV_Aveva_Telemetry Server_clientEd2_Certificate.pdf	119 KB	03/21/2022	Bruce Muschlitz
--	--------	------------	-----------------