

## IEC 61850 User Feedback Task Force - Improvement #5329

### Clarify iedType attribute usage in DataTypeTemplates

03/23/2022 10:46 AM - Camille Bloch

|   |                                 |                                |             |
|---|---------------------------------|--------------------------------|-------------|
| <b>Status:</b>  | Resolved                        | <b>Start date:</b>             | 03/23/2022  |
| <b>Priority:</b>  | Normal                          | <b>Due date:</b>               |             |
| <b>Category:</b>  | Standard clarification required | <b>% Done:</b>                 | 100%        |
| <b>Target version:</b>  |                                 | <b>Estimated time:</b>         | 0.00 hour   |
| <b>ID:</b>  |                                 | <b>To discuss in WG10:</b>     | No          |
| <b>Source:</b>  | SCL IOP 2021                    | <b>Short Proposal:</b>         |             |
| <b>TF Unique ID:</b>  |                                 | <b>Standard(s):</b>            | IEC 61850-6 |
| <b>WG10 Proposal:</b>   |                                 | <b>Needs More Information:</b> | No          |
| <b>Estimated Completion:</b>  |                                 | <b>Assigned TF:</b>            |             |
| <b>Discuss in Upcoming Meeting:</b>   | No                              |                                |             |
| <b>Description</b>  |                                 |                                |             |
| In IEC 61850-6 edition 2 amendment 1, iedType attribute in LNodeType has been deprecated and same attribute has been added to DType, but the paragraph explaining the usage of this attribute has not been updated. |                                 |                                |             |
| It has to be updated accordingly to new way of using this attribute   |                                 |                                |             |
| <b>Proposal descriptions</b>  |                                 |                                |             |
| To the editor of Part 6 - related paragraph to be updated through TISSUE process (editorial TISSUE).  |                                 |                                |             |

#### History

##### #1 - 03/29/2022 08:32 AM - Vladan Cvejic

- Category set to Standard clarification required
- Status changed from New to Resolved
- Proposal descriptions updated

##### #2 - 04/12/2022 09:20 AM - Vladan Cvejic

- % Done changed from 0 to 100
- Proposal descriptions updated

##### #3 - 05/09/2023 09:32 AM - Carlos Rodriguez del Castillo

- Needs More Information set to No

##### #4 - 05/09/2023 09:33 AM - Carlos Rodriguez del Castillo

- Discuss in Upcoming Meeting changed from No to Yes

##### #5 - 05/23/2023 08:41 AM - Carlos Rodriguez del Castillo

To be solved in 61850-6 ed2.2

##### #6 - 05/23/2023 08:42 AM - Carlos Rodriguez del Castillo

Tissue 1823

##### #7 - 06/05/2023 01:58 AM - Carlos Rodriguez del Castillo

- Discuss in Upcoming Meeting changed from Yes to No