

IEC 61850 User Feedback Task Force - Support #533

MSVID shall be unique. The integrated application SCD file allowed duplicate SVID's for two merging units.

02/03/2021 02:07 PM - Herbert Falk

Status: Closed	Start date:
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	
ID: 14	To discuss in WG10:
Source: IOP_2017/23	Short Proposal: WG10 to review how to check for unique IDs, particularly for fixed configuration devices.
TF Unique ID: 14 # IOP_2017/23	Standard(s):
WG10 Proposal:	Needs More Information:
Estimated Completion:	Assigned TF:
Discuss in Upcoming Meeting:	
Description	
MSVID shall be unique. The integrated application SCD file allowed duplicate SVID's for two merging units.	

History

#1 - 06/21/2022 09:13 AM - Carlos Rodriguez del Castillo

- Status changed from New to Closed

Confirm to IEC 61850-6 editor that this issue has been accounted for.