

IEC 61850 Certificate - IEC 61850 Certificate #5332

Easergy MiCOM P643 [Schneider Electric Industries SAS]

03/28/2022 04:47 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 089191 0035 Rev. 00
61850 Edition:	Edition 2	Certificate Hash:	SHA256: DD75DFC2C36F55B5AB1E5474F5402 DC907935935A20DD88C3148FC10283 D8620
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier, 92500 Rueil-Malmaison, France	Umbrella Organization:	Schneider
Product:	Easergy MiCOM P643	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	B7	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/25/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
Transformer Protection Relay			

Files

22-D 089191 0035_Schneider_P643_IEC61850Ed2_Server_Certificate.pdf	270 KB	03/28/2022	Bruce Muschlitz
--	--------	------------	-----------------