IEC 61850 Certificate - IEC 61850 Certificate #5332

Easergy MiCOM P643 [Schneider Electric Industries SAS]

03/28/2022 04:47 PM - Bruce Muschlitz

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	D 089191 0035 Rev. 00
61850 Tested Aspects:	Server	**Certificate Hash:**	SHA256: DD75DFC2C36F55B5AB1E5474F5402DC907935935A20DD88C3148FC10283D8620
Company:	Schneider Electric Industries SAS	**Vendor Artifact File Name:**	
Address:	35 rue Joseph Monier, 92500 Rueil-Malmaison, France	**Vendor Artifact Hash:**	
Product:	Easergy MiCOM P643	**Umbrella Organization:**	Schneider
HW Version:		**Optional Reservation Test:**	No
SW Version:	B7	**Serial Number:**	
Key Words:	Differential, Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	2.0.5	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	Bruce.Muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	03/25/2022	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	TUV SUD China Ltd (A)	**Product Variants:**	
Test Document:			

Description

Transformer Protection Relay

Files

22-D 089191 0035_Schneider_P643_IEC61850Ed2_Server_Certificate.pdf	272 KB	03/28/2022	Bruce Muschlitz