

IEC 61850 User Feedback Task Force - Feature #5336

Extension of the AddCause required to reflect communication issues in multi level control

04/01/2022 09:47 AM - Andreas Ostermeier

Status:	In Progress	Start date:	04/01/2022						
Priority:	Normal	Due date:							
Assignee:	Andreas Ostermeier	% Done:	0%						
Category:	Standard extension required	Estimated time:	0.00 hour						
Target version:		To discuss in WG10:	No						
ID:	4	Short Proposal:							
Source:	TF 61850-80-6	Standard(s):	IEC 61850-7-2; IEC 61850-8-1, 80-6						
TF Unique ID:	4 # 80-6	Needs More Information:	Yes						
WG10 Proposal:		Assigned TF:							
Estimated Completion:									
Discuss in Upcoming Meeting:	No								
Description <p>During the review of the control model of the Proxy/Gateway in IEC 61850-80-6 we found that the existing enumeration for the AddCause does not include values to reflect the situation where the Proxy/Gateway issues a negative confirmation to the control center client when the communication with the underlying IED that executes the command is disturbed, or the connection to the device is lost.</p> <p>This issue is not only relevant for the communication to the control center, but on always when the control action involves more than one communication level, e.g. Substation Scada to Breaker IED via an bay controller IED.</p> <p>Attached is a slide set which explains the need and proposes the new enumerated values for the AddCause.</p>									
Proposal descriptions <p>TF IEC 61850-80-6 proposed to extend the enumeration for the AddCause with 2 new ACSI values</p> <table><tr><td>ACSI value</td><td>MMS value</td></tr><tr><td>Communication-timeout</td><td>28</td></tr><tr><td>Communication-lost</td><td>29</td></tr></table>				ACSI value	MMS value	Communication-timeout	28	Communication-lost	29
ACSI value	MMS value								
Communication-timeout	28								
Communication-lost	29								
Related issues: <table><tr><td>Copied to IEC TC57 WG10 Future Work - WG10 Future Work #6578: Extension of th...</td><td>New</td><td>04/01/2022</td></tr></table>				Copied to IEC TC57 WG10 Future Work - WG10 Future Work #6578: Extension of th...	New	04/01/2022			
Copied to IEC TC57 WG10 Future Work - WG10 Future Work #6578: Extension of th...	New	04/01/2022							

History

#1 - 04/04/2022 08:17 AM - Andreas Ostermeier

- Standard(s) set to IEC 61850-7-2; IEC 61850-8-1

#2 - 04/26/2022 09:20 AM - Vladan Cvejic

- Status changed from New to In Progress

- Standard(s) changed from IEC 61850-7-2; IEC 61850-8-1 to IEC 61850-7-2; IEC 61850-8-1, 80-6

- (TF 80-6) Recommendation is to document use-cases and solution into the 80-6 document (to be part of its namespace)
- (Editor 7-2, 8-1) New AddCause values are suggested to be introduced into 7-2 and 8-1 in new edition (3) with detailed descriptions for acceptable use-cases.

#3 - 11/07/2023 03:49 AM - Vladan Cvejic

- Discuss in Upcoming Meeting changed from No to Yes

- Needs More Information set to Yes

#4 - 11/07/2023 08:27 AM - Vladan Cvejic

- Copied to WG10 Future Work #6578: Extension of the AddCause required to reflect communication issues in multi level control added

#5 - 11/07/2023 08:28 AM - Vladan Cvejic
- Discuss in Upcoming Meeting changed from Yes to No

Created a copy of issue in Future work project.

Files

AddCause.pdf	758 KB	04/01/2022	Andreas Ostermeier
--------------	--------	------------	--------------------