

IEC 61850 Certificate - IEC 61850 Certificate #5338

MiCOM P4 Agile P746 [UK Grid Solutions Limited]

04/04/2022 01:58 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6746.803
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 9B95F6CB709C36487E224B1FDE6488 DF7824A1BA4F9C207C76EBDDB396E A0CEC
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	UK Grid Solutions Limited	Vendor Artifact Hash:	
Address:	St. Leonards Building, Redhill Business Park, Stafford, ST16 IWT, United Kingdom	Umbrella Organization:	GE
Product:	MiCOM P4 Agile P746	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	91A	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/04/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		
Description			
Centralised Busbar Protection Relay			

Files

IEC 61850 Certificate Level B_50745.6746.803.pdf

219 KB

04/04/2022

Bruce Muschlitz