

Server - Issues #5343

sGosN2 remove PIXIT Gs5

04/12/2022 06:45 AM - Richard Schimmel

Status: Resolved	Due date:
Priority: Normal	
Assignee:	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: Server Ed2.0 TP2.0.7 and Server Ed2.1 TP1.3
Clause Reference:	Test Case ID: sGosN2
61850 Standard: 7-2	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Ed2Amd1 TP1.1 and Ed2 TP2.0.5	
Description	
The test description and expected result of sGosN2 do not refer to the PIXIT. What is the added value of the PIXIT entry? I propose to remove the PIXIT reference from sGosN2 and make the PIXIT entry Gs5 "Ed1" only.	
The expected result states: "DUT shall ignore the second GOOSE message with sqNum=0". No change required.	

History

#1 - 04/19/2022 11:07 AM - Bruce Muschlitz

Good catch! PIXIT Gs5 has NEVER been used (even in 2007 version of test procedures)

Agree to remove reference from test procedure sGosN2 and fix PIXIT row for Gs5:

- change column "Ed" from "1,2" to "-"

- add to "value/Clarification" column "This entry has never been used. sGosN2 specifies to ignore duplicates without any choice of behaviours."

#2 - 06/02/2022 03:05 PM - Bruce Muschlitz

- Status changed from *In Progress* to *Resolved*

- Updated Test Document set to Server Ed2.0 TP2.0.7 and Server Ed2.1 TP1.3