

Server - Issues #5344

sBr29 power-up the IED is missing

04/13/2022 09:44 AM - Richard Schimmel

Status:	Rejected	Due date:	
Priority:	Normal		
Assignee:			
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	
Clause Reference:		Test Case ID:	sBr29
61850 Standard:	7-2	Closed Reason:	No Action Taken
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:	Ed2Amd1 TP1.1 and Ed2 TP2.0.5		

Description

The test procedure does not perform a restart of the DUT. It's referring to PIXIT As8 restart time.

We propose to update the test description as follows:

Step 1: configure the device with a BRCB with a valid dataset and trigger option data change or integrity

Step 2: restart DUT and wait until the time specified in PIXIT As8.

Step 3: generate data change or wait for integrity report

Step 4: reserve and enable BRCB without resync

Expected result

step 4: All the reports in step 4 are buffered

History

#1 - 04/19/2022 04:37 AM - Thierry Dufaure

in sBr29, step 2 is already "wait untill startup is complete plus 3 integrity periods...".
How is the proposed restart adding advantages?

#2 - 06/02/2022 03:05 PM - Bruce Muschlitz

- Status changed from New to Closed
- Closed Reason No Action Taken added
- Closed Reason deleted (--Not Set--)

TPWG believes test procedure cannot be incorrectly interpreted as "restart now needed after reconfiguration"

#3 - 06/02/2022 04:12 PM - Herbert Falk

- Status changed from Closed to Rejected