IEC 61850 Certificate - IEC 61850 Certificate #5348

SAMU-1000 [KEPCO KDN]

04/29/2022 02:30 PM - Bruce Muschlitz

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Test Document:**	
61850 Tested Aspects:	Server	**Certificate Name:**	22TC200287
Company:	KEPCO KDN	**Certificate Hash:**	SHA256: 8460B9348EBDF4A8D12C17A80355597ED4FA54C26EABF029B45D1F5CE1AFC15F
Address:	661 Bitgaram-ro, Naju-si, Jeollanam-do, Republic of Korea	**Vendor Artifact File Name:**	
Product:	SAMU-1000	**Vendor Artifact Hash:**	
HW Version:	1.0	**Umbrella Organization:**	KEPCO
SW Version:	1.0	**Optional Reservation Test:**	No
Key Words:	Merging Unit	**Serial Number:**	
Test Procedure Version:	2.0.5	**Publisher Legacy Variants:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Rates:**	
Certificate/Result Reviewer:	Bruce.Muschlitz	**Publisher Preferred Variants:**	
Approval Date:	04/28/2022	**Subscriber Legacy Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Variants:**	
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	**Subscriber Preferred Rates:**	

Description

Merging unit

Files

22TC200287_KEPCOKDN_SAMU-1000_Server_Ed2_KERI_R1.pdf	180 KB	04/29/2022	Bruce Muschlitz