

IEC 61850 Certificate - IEC 61850 Certificate #5348

SAMU-1000 [KEPCO KDN]

04/29/2022 02:30 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	22TC200287
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 8460B9348EBDF4A8D12C17A8035559 7ED4FA54C26EABF029B45D1F5CE1A FC15F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	KEPCO KDN	Vendor Artifact Hash:	
Address:	661 Bitgaram-ro, Naju-si, Jeollanam-do, Republic of Korea	Umbrella Organization:	KEPCO
Product:	SAMU-1000	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Merging Unit	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/28/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
Merging unit			

Files

22TC200287_KEPCOKDN_SAMU-1000_Server_Ed2_KERI_R1.pdf 180 KB 04/29/2022 Bruce Muschlitz