

IEC 61850 Certificate - IEC 61850 Certificate #5349

MULTILIN T60 [M/s. GE T&D INDIA LIMITED]

05/02/2022 09:56 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASL22TC0002
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 64BD0EDABB2B8BFC28D1D01DC49F4 114D7B6D4DD84283FF5B373B18FB04 D681E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. GE T&D INDIA LIMITED	Vendor Artifact Hash:	
Address:	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI -- 600043, TAMIL NADU, INDIA	Umbrella Organization:	GE
Product:	MULTILIN T60	Optional Reservation Test:	
HW Version:	T60	Serial Number:	ABHC19001355
SW Version:	UR Family Version 8.05	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/28/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
Transformer Protection System			
Model number tested: T60W22HKHF8NH6DM8LP4LU8LW6U			

History

#1 - 05/02/2022 10:07 AM - Bruce Muschlitz

- Serial Number set to ABHC19001355

- Key Words Differential, Protection, Relay added

Files

CPRI-GE TandD INDIA Ltd -T60- CPRIBLRMUADSASL22TC0002.pdf .59 MB

05/02/2022

Bruce Muschlitz