

# IEC 61850 Certificate - IEC 61850 Certificate #5350

## G60 [M/s. GE T&D INDIA LIMITED]

05/02/2022 10:05 AM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	CPRIBLRMUADSASL22TC0003
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: CB2BB221A577E395A7912E97DB1263 F5FD60E7FF9F0249F9571CE5961B45 D4D5
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	M/s. GE T&D INDIA LIMITED	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI -- 600043, TAMIL NADU, INDIA	<b>Umbrella Organization:</b>	GE
<b>Product:</b>	G60	<b>Optional Reservation Test:</b>	
<b>HW Version:</b>	G60	<b>Serial Number:</b>	AALC21000558
<b>SW Version:</b>	UR Family Version 8.05	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/02/2022	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Description</b>			
Generator Protection System			
Model number tested: G60U03HKHF8LH6DM8MP67U67W67			

### Files

CPRI-GE TandD INDIA Ltd -G60- CPRIBLRMUADSASL22TC0003.pdf 1.6 MB

05/02/2022

Bruce Muschlitz