

IEC 61850 Certificate - IEC 61850 Certificate #5351

BCU-50-M [SAE IT-systems GmbH & Co. KG]

05/02/2022 10:29 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10331039-DSO 22-2796rev1
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 8A562A138C18B31051EF295F8731F0A 2BBB6031672488C603ECA8186920EF E98
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	SAE IT-systems GmbH & Co. KG	Vendor Artifact Hash:	
Address:	Im Gewerbegebiet Pesch 14 50767 Köln Germany	Umbrella Organization:	SAE
Product:	BCU-50-M	Optional Reservation Test:	Yes
HW Version:	3	Serial Number:	
SW Version:	07.002.00B	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/12/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
RTU			

Files

22-2796rev1_DNV_SAE-IT_BCU50-M_clientEd2_Certificate.pdf	121 KB	05/02/2022	Bruce Muschlitz
--	--------	------------	-----------------