

IEC 61850 Certificate - IEC 61850 Certificate #5351

BCU-50-M [SAE IT-systems GmbH & Co. KG]

05/02/2022 10:29 AM - Bruce Muschlitz

Status:	Approved	Certificate Name:	10331039-DSO 22-2796rev1
Priority:	Normal	Certificate Hash:	SHA256: 8A562A138C18B31051EF295F8731F0A 2BBB6031672488C603ECA8186920EF E98
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	SAE IT-systems GmbH & Co. KG	Umbrella Organization:	SAE
Address:	Im Gewerbegebiet Pesch 14 50767 Köln Germany	Optional Reservation Test:	Yes
Product:	BCU-50-M	Serial Number:	
HW Version:	3	Publisher Legacy Variants:	
SW Version:	07.002.00B	Publisher Preferred Rates:	
Key Words:	RTU	Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Rates:	
Approval Date:	04/12/2022	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
RTU			

Files

22-2796rev1_DNV_SAE-IT_BCU50-M_clientEd2_Certificate.pdf

121 KB

05/02/2022

Bruce Muschlitz