

# IEC 61850 Certificate - IEC 61850 Certificate #5361

## Mirage Servidor IEC 61850 [Controles S.A.]

05/12/2022 10:10 AM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10271907-DSO 22-2862
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: E0279F06FE70334ED13A4BF02E14F5 BA89069F965949EAF0D35197776CAF 840D
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Controles S.A.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Av. Rivera 3314 CP 11300 Montevideo Uruguay	<b>Umbrella Organization:</b>	Controles
<b>Product:</b>	Mirage Servidor IEC 61850	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	HP 240 G7 Notebook PC	<b>Serial Number:</b>	SCG0465N4V
<b>SW Version:</b>	2.12.0.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/22/2022	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
SCADA/HMI acquisition module			

### Files

22-2862\_DNV\_Controles\_Mirage\_Servidor\_clientEd2\_Certificate.pdf 119 KB

05/12/2022

Bruce Muschlitz