

IEC 61850 Certificate - IEC 61850 Certificate #5363

NP950: NPF955 [ICE SAS]

05/17/2022 04:40 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10344294-DSO 22-2877
61850 Edition:	Edition 2	Certificate Hash:	SHA256: C73D70C79F4036720AFC7838AD3338 42ABEAC55B308A4C03A018E48368ED 6E77
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ICE SAS	Vendor Artifact Hash:	
Address:	11 rue Marcel Sembat 94140 Alfortville France	Umbrella Organization:	
Product:	NP950: NPF955	Optional Reservation Test:	
HW Version:		Serial Number:	2211018877
SW Version:	v2.5.7.1	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/06/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description Feeder protection IED			

Files

22-2877_DNV_ICE_F955_variants_ServerEd2_Certificate.pdf	122 KB	05/17/2022	Bruce Muschlitz
---	--------	------------	-----------------