

IEC 61850 Certificate - IEC 61850 Certificate #5364

AQ-250: AQ-F255 [Arcteq Relays Ltd.]

05/17/2022 04:45 PM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10344294-DSO 22-2859
61850 Edition:	Edition 2	Certificate Hash:	SHA256: DFB393F50B81CA1647BE2E9FEEBA3 825A6C783E65724C51CD48928EC5EC C4B06
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Arcteq Relays Ltd.	Vendor Artifact Hash:	
Address:	Kvartsikatu 2A1 65300 Vaasa Finland	Umbrella Organization:	
Product:	AQ-250: AQ-F255	Optional Reservation Test:	
HW Version:		Serial Number:	2211018877
SW Version:	v2.5.7.1	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/06/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
Feeder protection IED			

Files

22-2859_DNV_Arcteq_F255_variants_ServerEd2_Certificate.pdf	122 KB	05/17/2022	Bruce Muschlitz
--	--------	------------	-----------------