

# IEC 61850 Certificate - IEC 61850 Certificate #5366

## MUST DM624 [WOODAM TECH CO., LTD.]

05/18/2022 09:33 AM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	22-024228-01-1
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 7E0B77CDC7A4155A9FF91C4E9B9343 B496843E15D2237763EAD61AAF07F1 5C09
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	WOODAM TECH CO., LTD.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	33, Daeposandan 1-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	MUST DM624	<b>Optional Reservation Test:</b>	
<b>HW Version:</b>	MUST DM624 ; OS: Embedded LINUX	<b>Serial Number:</b>	: WD-DM624-220001
<b>SW Version:</b>	1.000	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Measurement	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/16/2022	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
Gas Transformer Status Diagnosis IED			

### Files

22-024228-01-1\_WOODAM\_MUST DM624\_Server\_Ed2\_Certification.pdf

05/18/2022

Bruce Muschlitz