

IEC 61850 Certificate - IEC 61850 Certificate #5366

MUST DM624 [WOODAM TECH CO., LTD.]

05/18/2022 09:33 AM - Bruce Muschlitz

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	22-024228-01-1
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 7E0B77CDC7A4155A9FF91C4E9B9343 B496843E15D2237763EAD61AAF07F1 5C09
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	WOODAM TECH CO., LTD.	Vendor Artifact Hash:	
Address:	33, Daeposandan 1-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	MUST DM624	Optional Reservation Test:	
HW Version:	MUST DM624 ; OS: Embedded LINUX	Serial Number:	: WD-DM624-220001
SW Version:	1.000	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/16/2022	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
Gas Transformer Status Diagnosis IED			

Files

22-024228-01-1_WOODAM_MUST DM624_Server_Ed2_Certification.pdf

05/18/2022

Bruce Muschlitz