

# IEC 61850 Certificate - IEC 61850 Certificate #5369

## Multilin L90 [GE T&D India Limited]

05/27/2022 12:37 PM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	CPRIBLRMUADSASL22TC0005
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: C5DDCEC05CDBF7F3EDC2601641458 E2E84013700854FD60521DD403ED10 66059
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE T&D India Limited	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	19/1, G.S.T. Road, Pallavaram, Chennai - 600043, Tamil Nadu, India	<b>Umbrella Organization:</b>	GE
<b>Product:</b>	Multilin L90	<b>Optional Reservation Test:</b>	
<b>HW Version:</b>	L90 L90W03HKHF8LH6DL4LN4LS6UU6UW 2I	<b>Serial Number:</b>	AAZC21001912
<b>SW Version:</b>	UR Family Version 8.05	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/24/2022	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Description</b>			
Line Current Differential System			

### Files

CPRI-GE TandD INDIA Ltd -L90- CPRIBLRMUADSASL22TC0005.pdf 909 KB

05/27/2022

Bruce Muschlitz