

Server - Issues #5371

Scope of the test is limited to a given NSD release.

05/30/2022 07:36 AM - Thierry Dufaure

Status:	Closed	Due date:	
Priority:	Normal		
Assignee:			
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	
Clause Reference:	TP clause 2.2	Test Case ID:	
61850 Standard:	7-4	Closed Reason:	--Not Set--
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:	allow newer NSD	Triggering Tissue 3:	
Initial Test Document:	Ed2Amd1 TP1.2 and Ed2 TP2.0.6		
Description			
The test procedures Rev1.1 is limited to NSD 2007B3 - indicated in clause 2.2. Version 2007B3 of the name space definition (nsd) for IEC 61850 7-2, 7-3, 7-4, 8-1 and 9-2 ... Propose to change to Version 2007B3 or newer 2007B release of the name space definition (nsd) for IEC 61850 7-2, 7-3, 7-4, 8-1 and 9-2 ...			

History

#1 - 06/03/2022 04:50 AM - Richard Schimmel

- Initial Test Document set to Ed2Amd1 TP1.2 and Ed2 TP2.0.6
- 61850 Standard 7-4 added

I agree to allow newer NSD's.

#2 - 06/03/2022 04:50 AM - Richard Schimmel

- Status changed from New to In Progress

#3 - 06/14/2022 01:21 PM - Bruce Muschlitz

- Discuss in Upcoming Meeting changed from No to Yes

#4 - 06/29/2022 02:11 AM - Richard Schimmel

- Status changed from In Progress to Resolved
- Discuss in Upcoming Meeting changed from Yes to No
- Clause Reference set to TP clause 2.2
- Final Decision set to allow newer NSD

The TPWG agreed to change the last sentence in clause 2.2 from:

Version 2007B4 of the name space definition (nsd) for IEC 61850 7-2, 7-3, 7-4, 8-1 and 9-2 and the SCL schema version 2007B4 as published on <http://www.iec.ch/tc57/supportdocuments/>

Into:

Version 2007B4 **or newer** of the name space definition (nsd) for IEC 61850 7-2, 7-3, 7-4, 8-1 and 9-2 and the SCL schema version 2007B4 as published on <http://www.iec.ch/tc57/supportdocuments/>

#5 - 03/01/2024 09:52 AM - Richard Schimmel

- Status changed from Resolved to Closed