

IEC 61850 Certificate - IEC 61850 Certificate #5373

MULTILIN B90 [M/s. GE T&D INDIA LIMITED]

06/01/2022 01:44 PM - Bruce Muschlitz

Status:	Approved	Certificate Name:	CPRIBLRMUADSASL22TC0006
Priority:	Normal	Certificate Hash:	SHA256: 8A44FCC54FF0EC8F7D34B346498261 4C0056DD74E997B3608CAE88231CD C9F29
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	M/s. GE T&D INDIA LIMITED	Umbrella Organization:	
Address:	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI – 600043, TAMIL NADU, INDIA	Optional Reservation Test:	
Product:	MULTILIN B90	Serial Number:	AA6C18001553
HW Version:	B90	Publisher Legacy Variants:	
SW Version:	UR Family Version 8.05	Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	2.0.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Bruce.Muschlitz	Subscriber Preferred Rates:	
Approval Date:	05/30/2022	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Test Document:			
Description Bus Differential System			

Files

CPRI-GE TandD INDIA Ltd -B90- CPRIBLRMUADSASL22TC0006.pdf 864 KB

06/01/2022

Bruce Muschlitz