

# IEC 61850 Certificate - IEC 61850 Certificate #5377

## MM300 [GE Renewable Energy]

06/10/2022 08:32 AM - Bruce Muschlitz

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	50745.6MM300.801
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 384A6B864D29B9471759FE50130065D E6FCFB8E1C69966F7D76E36945ADD3 A70
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Renewable Energy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST161WT	<b>Umbrella Organization:</b>	GE
<b>Product:</b>	MM300	<b>Optional Reservation Test:</b>	
<b>HW Version:</b>	A	<b>Serial Number:</b>	
<b>SW Version:</b>	2.0 ; IEC 61850 Version: 2.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Bruce.Muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/10/2022	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Grid Automation Laboratories (B)		
<b>Description</b>			
Enhanced Motor Management System			

### Files

50745.6MM300.801\_GE\_MM300\_Enhanced\_V2.0\_Edition2\_Certificate.pdf KB

06/10/2022

Bruce Muschlitz