

IEC 61850 User Feedback Task Force - Feature #573

Tap Changer Supervision: Tap discrepancy (3 pole transformer case)

02/03/2021 02:07 PM - Herbert Falk

Status:	Closed	Start date:	
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:	Standard extension required	Estimated time:	0.00 hour
Target version:		To discuss in WG10:	No
ID:	45	Short Proposal:	To have similar solution like Pole discrepancy in XCBR (to extend YLTC)19-01-23: To create Use-case with different scenarios in order to clearly define scope of application (V.Cvejic) To be addressed by TF 7-5 (approval and deffinition what has to be done)
Source:	ENTSO-E	Standard(s):	IEC 61850-7-4
TF Unique ID:	45 # ENTSO-E	Needs More Information:	Yes
WG10 Proposal:		Assigned TF:	
Estimated Completion:	19-01-23: To create Use-case with different scenarios in order to clearly define scope of application (Vladan C) To send for comments to H31.		
Discuss in Upcoming Meeting:	No		

Description
Tap Changer Supervision: Tap discrepancy (3 pole transformer case)
There is a need to model this functionality in IEC 61850.

History

#1 - 02/03/2021 02:51 PM - Herbert Falk

- Status changed from New to In Progress

#2 - 02/11/2021 07:14 AM - Vladan Cvejic

- Description updated

- Short Proposal changed from To have similar solution like Pole discrepancy in XCBR (to extend YLTC) 19-01-23: To create Use-case with different scenarios in order to clearly define scope of application (V.Cvejic) To be addressed by TF 7-5 (approval and deffinition what has to be done) to To have similar solution like Pole discrepancy in XCBR (to extend YLTC)19-01-23: To create Use-case with different scenarios in order to clearly define scope of application (V.Cvejic) To be addressed by TF 7-5 (approval and deffinition what has to be done)

- Standard(s) set to IEC 61850-7-4

- Discuss in Upcoming Meeting set to No

Checking done.

#3 - 12/06/2022 09:36 AM - Vladan Cvejic

- Status changed from In Progress to Closed

- To discuss in WG10 set to No

- Needs More Information set to Yes

Since there is no representation from ENTSO-E anymore we can close these tickets for now. Additionally, we can eventually re-open if in the future similar needs are identified by other users.