

IEC 61850 User Feedback Task Force - Feature #577

Switch on to Fault PSOF logical node

02/03/2021 02:07 PM - Herbert Falk

Status: Closed	Start date:
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category: Standard extension required	Estimated time: 0.00 hour
Target version:	To discuss in WG10:
ID: 49	Short Proposal: To revise PSOF LN
Source: ENTSO-E	Standard(s): IEC 61850-7-4
TF Unique ID: 49 # ENTSO-E	Needs More Information:
WG10 Proposal: No issue. The Op DO is always ACT. Str DO is ACD. The direction information can be retrieved from Str DO.	Assigned TF:
Estimated Completion: 2019-06	
Discuss in Upcoming Meeting: No	

Description

Switch on to Fault: operate by SOTF (FW) and SOTF (BW)
PSOF LN is related to Switch onto fault and there is Str (ACD) where, for example, logic:
PSOF.Str.dirGeneral == Forward / Backward

could create both Operate by SOTF and Operate by SOTF respectively.

History

#1 - 02/03/2021 02:47 PM - Herbert Falk

- Status changed from New to Closed

#2 - 02/09/2021 06:24 AM - Carlos Rodriguez del Castillo

- Subject changed from Switch on to Fault: operate by SOTF (FW) and SOTF (BW)
PSOF LN is related to Switch onto fault and there is Str (ACD) where, for to Switch on to Fault PSOF logical node

#3 - 02/11/2021 06:02 AM - Vladan Cvejic

- Description updated
- Standard(s) set to IEC 61850-7-4
- Discuss in Upcoming Meeting set to No

Checking done.