

WG16 Issues - CIM Issues #5791

WG21 Request: RegisteredDistributedResources require a priority to be defined.

06/23/2022 10:33 AM - Herbert Falk

Status:	Closed	
Priority:	Normal	
Target version:		
Author/Contact Info:	Becky	Standard(s):
Base Release:	iec61970cim17v16iec61968cim13v09iec62325cim04v01	Version:
Solution to be Applied To:		Clause: RegisteredDistributedResource
Solution Version:	iec61970cim17v34ec61968cim13v12iec62325cim04v06_draft2	Sub-Clause:
Solution Applied By:	BLI	Paragraph:
Completion Date:	12/09/2021	Table:
CIM Keywords:		Originally Closed in Version:
Breaking Change:		Origination Date: 11/18/2019
Breaking Change Description:		Origination ID: 16_0075
CIM Impacted Groups:	None	Originally Assigned To:
Requestor:		
Description		
WG21 Request: RegisteredDistributedResources require a priority to be defined.		
Proposed Solution		
Add new attribute to class RegisteredDistributedResource. Add new attribute priority. Provides for the setting of priority of power supply for the RegisteredDistributedResources. For example, priority can be set for each building to show the priority of Power Supply. The district manager can confirm a priority of each building in the district by the RegisteredDistributedResource.priority.		
Decision		
Added new attribute		

History

#1 - 08/08/2022 05:37 PM - Becky Iverson

- Status changed from New to Closed

- Solution Version changed from iec61970cim17v34ec61968cim13v12

iec62325cim04v06_draft2 to iec61970cim17v34ec61968cim13v12iec62325cim04v06_draft2