

WG16 Issues - CIM Issues #5800

Add meteringMethod attribute (String) in the MarketEvaluationPoint class

06/23/2022 10:33 AM - Herbert Falk

| | |
|--|--------------------------------------|
| Status: Closed | |
| Priority: Normal | |
| Target version: | |
| Author/Contact Info: Jan (eBIX 2019/4) | Standard(s): |
| Base Release: iec61970cim17v34_iec61968cim13v12_iec62325cim04v07 | Version: |
| Solution to be Applied To: | Clause: MarketEvaluationPoint |
| Solution Version: iec61970cim17v34_iec61968cim13v12_iec62325cim04v15 | Sub-Clause: |
| Solution Applied By: Becky Iverson | Paragraph: |
| Completion Date: 10/10/2023 | Table: |
| CIM Keywords: | Originally Closed in Version: |
| Breaking Change: | Origination Date: 12/18/2019 |
| Breaking Change Description: | Origination ID: 16_0084 |
| CIM Impacted Groups: None | Originally Assigned To: |
| Requestor: | |
| Description | |
| Add meteringMethod attribute (String) in the MarketEvaluationPoint class [0..1]. | |
| This will inform the Energy supplier how the energy volumes for the MarketEvaluationPoint are established, are they from a continuous read meter, a non-continuous read meter (e.g. yearly read/manually entered at a website), calculated or not-metered (e.g. for street lights where the energy volume doesn't come from any meter at all)? | |
| Proposed Solution | |
| Suggested definition: Specifies how the energy volumes are established for the Market Evaluation Point, such as continuous, non-continuous, calculated, or not-metered. 5/6: Attribute for AccountingPoint class | |
| Decision | |
| 3/24/2022: Planned to be modeled in MarketManagement package. | |
| Release Notes | |
| MarketEvaluationPoint added attribute measurementMethod | |

History

#1 - 08/08/2022 05:43 PM - Becky Iverson

- Status changed from New to Open
- Proposed Solution updated

#2 - 09/21/2022 02:38 PM - Becky Iverson

- Status changed from Open to In Progress

#3 - 08/21/2023 01:56 AM - Jan Owe

Discussed in European CIM for retail market WG 2022-02-16. The attribute name changed to measurementMethod.

#4 - 10/10/2023 05:07 PM - Becky Iverson

- Status changed from In Progress to Review

- *Solution Version set to iec61970cim17v34_iec61968cim13v12_iec62325cim04v15*
- *Solution Applied By set to Becky Iverson*
- *Completion Date set to 10/10/2023*
- *Release Notes updated*

#5 - 10/13/2023 04:14 PM - Becky Iverson

- *Status changed from Review to Closed*