

IEC 61850 User Feedback Task Force - Feature #587

LNodeTypes and DOTypes not used in the IED section - is it allowed to keep them in DataTypeTemplate section?

02/03/2021 02:07 PM - Herbert Falk

| | |
|--|--|
| Status: Closed | Start date: |
| Priority: Normal | Due date: |
| Assignee: | % Done: 0% |
| Category: Solved / Missunderstanding | Estimated time: 0.00 hour |
| Target version: | To discuss in WG10: |
| ID: 1404 | Short Proposal: Unused types may be removed by the SCT. No guarantee that they are conserved in the SCD file. |
| Source: IOP_2019 | Standard(s): IEC 61850-6 |
| TF Unique ID: 1404 # IOP_2019 | Needs More Information: |
| WG10 Proposal: It is allowed to maintain unused data types so the tool must handle it. No standard issue. | Assigned TF: |
| Estimated Completion: | |
| Discuss in Upcoming Meeting: No | |

Description

In DataTypeTemplate, 125 LNodeTypes are not used in the IED section of the ICD file.

Example of error :

ERROR: [SemanticConstraints] Unused LNodeType (id=LLN0_4) (line 156483) there is no LN or LNode referring this LNodeType

In addition, 3 DOTypes are not used in the IED section of the ICD file.

Example of error :

ERROR: [SemanticConstraints] Unused DOType (id=ENC_0) (line 161929) there is no DO or SDO referring this DOType

Is it allowed / usefull to keep all these unused LNodeTypes and DOTypes in the DataTypeTemplate section ?

History

#1 - 02/11/2021 07:01 AM - Vladan Cvejic

- Subject changed from In DataTypeTemplate, 125 LNodeTypes are not used in the IED section of the ICD file.

Example of error :

ERROR: [SemanticConstrai to LNodeTypes and DOTypes not used in the IED section - is it allowed to keep them in DataTypeTemplate section?

- Status changed from New to Closed

- Standard(s) changed from 6 to IEC 61850-6

- Discuss in Upcoming Meeting set to No

Checking done.