

## IEC TC57 WG10 Future Work - WG10 Future Work #5878

### Technical reports to be considered in edition 3 of IEC 61850-7-4

07/05/2022 10:49 AM - Henry Dawidczak

<b>Status:</b>	New	<b>Start date:</b>	07/05/2022
<b>Priority:</b>	Normal	<b>Due date:</b>	
<b>Assignee:</b>		<b>% Done:</b>	0%
<b>Category:</b>		<b>Estimated time:</b>	0.00 hour
<b>Target version:</b>			
<b>Source:</b>		<b>Standard(s):</b>	IEC 61850-7-4
<b>TF Unique ID:</b>		<b>Needs More Information:</b>	No
<b>WG10 Proposal:</b>		<b>Assigned TF:</b>	61850-7-4
<b>Discuss in Upcoming Meeting:</b>	No	<b>Target edition:</b>	Next
<b>Short Proposal:</b>			

**Description**

The following TR should/shall be considered in IEC 61850-7-4 ed.3.0:

- IEC 61850-90-3 - Condition monitoring diagnosis and analysis
- IEC 61850-90-4 - Network engineering guidelines (data model for bridges, clocks)
- IEC 61850-90-6 - Distribution Automation Systems
- IEC 61850-90-11 - Logic modelling, some extensions in GAPC
- IEC 61850-90-14 - FACTS, HVDC transmission and power conversion data modelling
- IEC 61850-90-17 - PQ models
- IEC 61850-90-18- Alarm handling
- IEC 61850-90-21- Traveling wave modeling
- IEC 61850-90-28- Communication supervision data model extensions
- IEC 61850-90-29 - Physical resources (LPDI, LPDO, LRUT, LPPS, ...)

#### History

##### #1 - 07/05/2022 10:54 AM - Henry Dawidczak

Something went wrong with formatting.

##### #2 - 07/12/2022 08:54 AM - Vladan Cvejic

- Description updated

##### #3 - 07/12/2022 08:58 AM - Vladan Cvejic

- Description updated

Henry Dawidczak wrote in [#note-1](#):

Something went wrong with formatting.

Redmine is using markup language for formatting so minus glued to text means ~~Striked~~ and so on. I just selected all entries and chose editing option for Unordered list . (it will be shown as star before text - bullets will come after saving).

- text1
- text2

##### #4 - 06/21/2023 02:23 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work

- Assignee deleted (WG10 Future Work Administrators)

- Needs More Information set to No

- Target edition set to Edition 3

- Assigned TF None added

**#5 - 10/26/2023 02:37 AM - Vladan Cvejic**

- Target edition changed from Edition 3 to Not assigned

**#6 - 02/08/2024 05:20 AM - Vladan Cvejic**

- Standard(s) set to IEC 61850-7-4

- Target edition changed from Not assigned to Next

- Assigned TF 61850-7-4 added

- Assigned TF deleted (None)