

IEC 61850 Certificate - IEC 61850 Certificate #5879

ZLFC [ZIV Aplicaciones y Tecnología SL]

07/05/2022 07:37 PM - Bruce Muschlitz

| | | | |
|-------------------------------------|---|---------------------------------------|---|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 10360766-DSO 22-2950rev1 |
| 61850 Edition: | Edition 2 | Certificate Hash: | SHA256: 2685960ED868B8FDCE8B447F37EFF1 42F4D0D8799B0D85757C00CDECEDF 74DE2 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | ZIV Aplicaciones y Tecnología SL | Vendor Artifact Hash: | |
| Address: | Parque Tecnológico de Bizkaia, 210 48170 Zamudio, Vizcaya Spain | Umbrella Organization: | ZIV |
| Product: | ZLFC | Optional Reservation Test: | |
| HW Version: | ZLFC2A2472BH000000C012 | Serial Number: | 215111 |
| SW Version: | 0.10.0 | Publisher Legacy Variants: | - |
| Key Words: | Distance, Protection, Relay | Publisher Preferred Rates: | - |
| Test Procedure Version: | 2.0.5 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | - |
| Certificate/Result Reviewer: | Bruce.Muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 05/26/2022 | Subscriber Preferred Rates: | - |
| Standards Tested: | 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Description | | | |

Files

22-2950rev1_DNV_ZIV_ZLFC_IRF_DBF_ServerEd2_Certificate.pdf 122 KB 07/06/2022 Bruce Muschlitz