

CIM Issues - CIM Issues #5884

Modify control model - create DiscreteCommand for enumerations such as raise/lower

07/13/2022 10:45 AM - Tom Berry

Status:	New	
Priority:	Normal	
Target version:		
Solution Version:		Sub-Clause:
CIM Impacted Groups:	WG13	Paragraph:
Requestor:	Tom Berry	Table:
Standard(s):		Origination Date: 07/13/2022
Version:		Origination ID: IEC TS 62361-102 Recommendation R18
Clause:		Originally Assigned To:
Description IEC TS 62361-102 Recommendation R18 See Figures 16 and 17 The changes are: <ul style="list-style-type: none">• Generalized Raise/Lower into a DiscreteCommand. The DiscreteCommand allows an enumerated control to be sent, and the MeasurementValue whose value should change based upon the control, to be specified.• The value and normalValue attributes in Command were removed and equivalent attributes of the appropriate type, were placed into DiscreteCommand and AnalogControl.		

Files

IEC-TS-62361-102-Ed1 Harmonization-RecommendationsR18 ControlModels.pdf	07/13/2022	Tom Berry
---	------------	-----------