

## WG13 Issues - CIM Issues #5893

### CDPSM conflicting roles HydroPowerPlant.HydroPumps and HydroPump.HydroPowerPlant

07/13/2022 02:13 PM - Martin Miller

<b>Status:</b> New	
<b>Priority:</b> Normal	
<b>Target version:</b>	
<b>Author/Contact Info:</b>	<b>Standard(s):</b> 61968-13
<b>Base Release:</b>	<b>Version:</b> 2
<b>Solution to be Applied To:</b>	<b>Clause:</b> 6.3.2.63
<b>Solution Version:</b>	<b>Sub-Clause:</b>
<b>Solution Applied By:</b>	<b>Paragraph:</b>
<b>Completion Date:</b>	<b>Table:</b>
<b>CIM Keywords:</b>	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b>	<b>Origination Date:</b>
<b>Breaking Change Description:</b>	<b>Origination ID:</b>
<b>CIM Impacted Groups:</b> WG13	<b>Originally Assigned To:</b>
<b>Requestor:</b>	
<b>Description</b> The role HydroPowerPlant.HydroPumps in section 6.3.2.63 is in conflict with the role HydroPump.HydroPowerPlant in section 6.3.2.64 because they are both roles of the same relationship	
<b>Proposed Solution</b> Given that model manager guidance usually promotes 0..1 roles over 0..* roles, remove the role HydroPowerPlant.HydroPumps in section 6.3.2.63 and preserve the role HydroPump.HydroPowerPlant in section 6.3.2.64	