

Server - Issues #5906

sCnf51 at least one LPHD

07/20/2022 07:54 AM - Richard Schimmel

Status:	Rejected	Due date:	09/06/2022
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	
Clause Reference:	8.2.5	Test Case ID:	
61850 Standard:	7-1	Closed Reason:	No Action Taken
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:	rejected	Triggering Tissue 3:	
Initial Test Document:	Amd1 TP1.2		

Description

Part 7-1 clause 8.2.1 states "at least one LPHD" shall be available in a server device.

The sCnf51 test procedure requires:
"LPHD is present in **each** root logical device"

Propose to change into:
"LPHD is present in **at least one** root logical device"

and change the clause reference to 8.2.1

History

#1 - 08/09/2022 08:22 AM - IEC 61850 TPWG

- Due date set to 09/06/2022
- Status changed from New to Resolved
- Assignee set to Richard Schimmel
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

Update TP to at least one

#2 - 08/10/2022 03:57 PM - Joel Greene

- Status changed from Resolved to In Progress

Hmmm...

"LPHD is present in each root logical device" comes from 8.2.5 which defines root as not having GrRef.

#3 - 08/11/2022 01:51 AM - Richard Schimmel

Indeed part 7-1 clause 8.2.5 is very specific: "LPHD shall be present in any root logical device". Propose to reject/close this issue, no change.

#4 - 08/11/2022 01:55 AM - Richard Schimmel

- Status changed from In Progress to Rejected
- Clause Reference set to 8.2.5
- Final Decision set to rejected
- Test Case ID deleted (sCnf51)

- *Closed Reason No Action Taken added*
- *Closed Reason deleted (Test Procedure Update)*

Rejected, keep sCnf51 as is.

#5 - 09/06/2022 08:20 AM - IEC 61850 TPWG

Reject confirmed