

Server - Issues #5907

sCtl26 - Cancel a direct control object

07/21/2022 07:50 AM - Richard Schimmel

Status:	Closed	Due date:	
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	Yes	Updated Test Document:	TP1.3
Clause Reference:		Test Case ID:	sCtl26
61850 Standard:		Closed Reason:	Test Procedure Update
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:	Amd1 TP1.2		
Description			
The test condition for sCtl26 is: command-already-in-execution and operateTimeout>0. However the (direct) control object also should have a Cancel structure. Proposal change condition into: command-already-in-execution, operateTimeout and Cancel			

History

#1 - 08/09/2022 08:24 AM - IEC 61850 TPWG

- Status changed from New to Resolved
- Assignee set to Richard Schimmel
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

Add condition as described.

#2 - 03/01/2024 09:53 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3