

IEC 61850 Certificate - IEC 61850 Certificate #5909

VITZRO EM CO., LTD. VIPAM-PB

07/24/2022 02:54 PM - Herbert Falk

| | | | |
|--|---|---------------------------------------|--|
| Status: | Approved | Test Document: | Edition 2 Server Test Procedures version 2.0.6 |
| Priority: | Normal | Certificate Name: | 22-038521-01-1_VITZERO EM_VIPAM-PB_Server_Ed2_Certificatio n_KTL.pdf |
| 61850 Edition: | Edition 2 | Certificate Hash: | 4F26D12305BD6BFFCE6162F1055ED3 3EC2D8D393E9F9A20C90E0EBB1364F 9B04 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | VITZRO EM CO., LTD. | Vendor Artifact Hash: | |
| Address: | 04998, VITZRO GROUP B/D, 7 Neungdong-ro 25-gil, Gwangjin-gu, Seoul, Republic of Korea | Umbrella Organization: | |
| Product: | VIPAM-PB | Optional Reservation Test: | No |
| HW Version: | VIPAM-PBAS OS: VIPAM-PBAS OS | Serial Number: | |
| SW Version: | 1.0 | Publisher Legacy Variants: | - |
| Key Words: | Relay | Publisher Preferred Rates: | - |
| Test Procedure Version: | 2.06 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Data Sets (B2), Direct Control (12a), File Transfer (B14), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | - |
| Certificate/Result Reviewer: | Herbert Falk | Subscriber Preferred Variants: | |
| Approval Date: | 07/24/2022 | Subscriber Preferred Rates: | - |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | Korea Testing Laboratory (A) | | |
| Description VITZRO EM CO., LTD. VIPAM-PB | | | |

History

#1 - 07/24/2022 03:11 PM - Herbert Falk

- Approval Date set to 07/24/2022

Files

| | | |
|--|------------|--------------|
| 22-038521-01-1_VITZERO EM_VIPAM-PB_Server_Ed2_Certification_0076.kbf | 07/24/2022 | Herbert Falk |
|--|------------|--------------|