

# IEC 61850 Certificate - IEC 61850 Certificate #5918

## MiCOMP40AgileP44T Edition 2 Server

08/02/2022 12:18 PM - Herbert Falk

|                                     |  |                                       |  |
|-------------------------------------|--|---------------------------------------|--|
| <b>Status:</b>                      | Approved   | <b>Test Document:</b>                 | Server 2.0.5   |
| <b>Priority:</b>                    | Normal   | <b>Certificate Name:</b>              | 50745.644T.805_P44T_91B_IEC61850<br>ED2_Server_Certificate.pdf           |
| <b>61850 Edition:</b>               | Edition 2  | <b>Certificate Hash:</b>              | 85FA9E362FF6FF8F014D01CB920F42<br>30882E0E2C553AF1FEAEE017D29360<br>B5DA |
| <b>61850 Tested Aspects:</b>        | Server   | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>                     | UKGridSolutionsLimited   | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>                     | St.LeonardsBuilding,RedhillBusinessPar<br>k,<br>Stafford,ST161WT,UnitedKingdom   | <b>Umbrella Organization:</b>         |  |
| <b>Product:</b>                     | MiCOMP40AgileP44T  | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>                  | M  | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>                  | 91B  | <b>Publisher Legacy Variants:</b>     | -  |
| <b>Key Words:</b>                   | Distance, Relay  | <b>Publisher Preferred Rates:</b>     | -  |
| <b>Test Procedure Version:</b>      | 2.0.5  | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>  | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    | -  |
| <b>Certificate/Result Reviewer:</b> | Herbert Falk   | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>               | 08/02/2022   | <b>Subscriber Preferred Rates:</b>    | -  |
| <b>Standards Tested:</b>            | 61850-6, 61850-7-1, 61850-7-2,<br>61850-7-3, 61850-8-1   |                                       |  |
| <b>Current Test Lab Name:</b>       | Grid Automation Laboratories (B)   |                                       |  |
| <b>Description</b>                  |  |                                       |  |
| MiCOMP40AgileP44T Edition 2 Server  |  |                                       |  |

### History

#### #1 - 08/04/2022 06:56 AM - Herbert Falk

- File 50745.644T.805\_P44T\_91B\_IEC61850 ED2\_Server\_Certificate.pdf added

- Certificate Name changed from 50745.644T.108\_P44T\_91B\_IEC61850 ED2\_Server\_Certificate Level B\_TP2.0.5.pdf to 50745.644T.805\_P44T\_91B\_IEC61850 ED2\_Server\_Certificate.pdf

- Certificate Hash changed from FDE2031C48134656272EE8D21F1008FEEC50D4E9E8CCB3BBFF88611E463076DA to 85FA9E362FF6FF8F014D01CB920F4230882E0E2C553AF1FEAEE017D29360B5DA

#### #2 - 08/04/2022 06:56 AM - Herbert Falk

- File deleted (50745.644T.108\_P44T\_91B\_IEC61850 ED2\_Server\_Certificate Level B\_TP2.0.5.pdf)

**Files**

---

50745.644T.805\_P44T\_91B\_IEC61850 ED2\_Server\_Certificate.pdf 217 KB 08/04/2022 Herbert Falk