

IEC 61850 Certificate - IEC 61850 Certificate #5919

DS Agile aView Edition 2 Client

08/05/2022 10:39 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Conformance Test Procedures version 1.2
Priority:	Normal	Certificate Name:	22-3027_DNV_GE_aView_clientEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	4DA2FBDDCDDC2348E5FCF104D6D5604FF2217989A2D75ACBF0D0AB8A78817CF7
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	GE Grid Solutions	Vendor Artifact Hash:	
Address:	Parc Eureka 81 rue Euclide - CS 11140 34060 Montpellier Cedex 2 France	Umbrella Organization:	
Product:	DS Agile aView	Optional Reservation Test:	Yes
HW Version:	Dell precision tower 5810 with Windows 10 Enterprise LTSC	Serial Number:	10366551-DSO 22-3027
SW Version:	V7	Publisher Legacy Variants:	-
Key Words:	HMI	Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	08/05/2022	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
DS Agile aView Edition 2 Client			

Files

22-3027_DNV_GE_aView_clientEd2_Certificate.pdf	106 KB	08/05/2022	Herbert Falk
--	--------	------------	--------------