

# IEC 61850 Certificate - IEC 61850 Certificate #5920

## Kalki SYNC 3000 Edition 2 Client

08/05/2022 10:52 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Client Conformance test Procedures version 1.2
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	22-2984_DNV_Kalkitech_SYNC3000_clientEd2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	26A6F0FE6F053697C073390A186F8AB4584CA6528DA4C87F1F8A5DD4B7533CAE
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Kalki Communication Technologies	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Pvt Ltd. (Kalkitech) 17/1, The Address, 4th Floor, Outer Ring Road, Kadubeesanahalli Bangalore 560103 India	<b>Umbrella Organization:</b>	
<b>Product:</b>	SYNC 3000	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	S/N: BKB000043000020	<b>Serial Number:</b>	10366543-DSO 22-2984
<b>SW Version:</b>	GPC 4.17.1	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Gateway, RTU	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/05/2022	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

SYNC 3000 Substation Data Concentrator/ Secure Substation Gateway

### Files

22-2984_DNV_Kalkitech_SYNC3000_clientEd2_Certificate.pdf	121 KB	08/05/2022	Herbert Falk
--	--------	------------	--------------