

IEC TC57 WG10 Future Work - WG10 Future Work #5930

CIM-61850 Harmonization - mRID attribute in SCL for Equipment, Terminals, ConnectivityNodes

08/09/2022 08:06 AM - Vladan Cvejic

Status: New	Start date: 07/13/2022
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	Standard(s): IEC 61850-6
Source: IEC 62361-102 R6	Needs More Information: No
TF Unique ID:	Assigned TF: 61850-6
WG10 Proposal:	Target edition: Next
Discuss in Upcoming Meeting: No	
Short Proposal:	
Description IEC 62361-102 recommendation R6 Add mRID to SCL as an optional attribute to type tBaseElement in SCL_BaseTypes.xsd allowing mRIDS to be defined for Equipment, Terminals and ConnectivityNodes	
Proposal descriptions add mRID to SCL type tBaseElement	

History

#1 - 09/13/2022 08:17 AM - Carlos Rodriguez del Castillo

- Discuss in Upcoming Meeting changed from Yes to No

#2 - 06/21/2023 02:21 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work

- Needs More Information set to No

- Target edition set to Edition 3

- Assigned TF 61850-6 added

#3 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition changed from Edition 3 to Not assigned

#4 - 02/08/2024 05:08 AM - Vladan Cvejic

- Target edition changed from Not assigned to Next